

**Bias Test of the Clean Coal Sampling System  
at Crossville Coal, Inc.**

Mike Webster, Mine Manager  
Rick Schubert, Quality Control Manager  
6728 Smith Mountain Rd  
Crab Orchard, TN 37723  
(931) 707-8032 ext 24

February 15, 2006

Prepared by

Stephen R. Smith  
Coalsmith Consultants  
6848 Hampton Wood Cr  
Hixson, TN 37343  
423-843-1815

## 1.0 Introduction

This report gives the results of a test for bias in the Crossville Coal clean coal sample system. A total of 17 sets of samples were collected from November 15, 2005 through February 1, 2006. Collection of stopped-belt reference samples and mechanical system save samples was performed by Rick Schubert, Quality Control Manager of Crossville Coal and Stephen Smith of Coalsmith Consultants.

This is a test of a sample system on the clean coal belt from a wash plant. Coal is mined using continuous miners in the Sewanee Seam. Raw coal goes through a rotary breaker with 4 inch openings. Coal is screened at 2 inch, and +2 inch is crushed and recycled to the screen. Two inch by 16 mesh coal is washed in a heavy medium cyclone circuit, with spirals for 16 mesh x 100 mesh. The 100 mesh x 0 coal is rejected and filtered in a belt press. The sampler tested is on the 36 inch wide, horizontal, clean coal belt.

Coal samples were dried, prepared, and analyzed at Standard Laboratories in Jacksboro, TN using ASTM methods of preparation and analysis. Procedures for the bias test conformed to the standard bias test procedure in ASTM D6518. Calculation of results of the test were performed using Datawolff Bias Test spreadsheet add-in script provided by Wolffware, Ltd. Test logs, coal analysis, calculations, and photographs of the system tested are attached.

## 2.0 Description of Sampling System

Manufacturer.....	Ramsey Engineering
Year installed.....	1997
No. of sampling stages.....	2
Primary Sampling Stage	
Type.....	Sweep arm cutter
Drive.....	Electric
Cutter opening.....	12 inches
Operating interval.....	120 seconds
Primary Feeder	
Type.....	Chute
Crusher	
Manufacturer.....	Ramsey
Type.....	Minimill
Secondary Sampling Stage	
Drive System.....	Electric
Type.....	Sweep arm cutter
Cutter opening .....	2 inches
Operating interval.....	13 seconds

## 3.0 Options Selected in Test Design

The bias testing procedure offers options to the user. The following options were selected:

- a) Coal Characteristics for the test were moisture, ar ash, ar sulfur, and ar Btu.
- b) An 80-minute test batch interval was chosen. This provided a target system save sample weighing 1000 grams at 8 mesh.
- c) A total of 30 test pairs were planned for and 17 pairs were collected.
- d) Two stopped-belt reference increments were collected and combined from each test batch of coal. Pre-selected random sample collection times (for each test batch) were followed during

the test. These reference samples were crushed to 8-mesh, riffled, and analyzed concurrently with the system save samples.

#### 4.0 Results of the Test for Independent Differences

Individual differences between laboratory analyses of reference and laboratory analysis of system samples were examined to see if there was evidence that revealed they may not be independent. Should the assumption of independence not be true, conclusions drawn from the test using all sets of data to determine confidence intervals might be suspect.

The number of differences above (+) and below (-) the median difference, the low (l) and upper (u) table values, and the number of runs (r) found for each coal characteristic, are given below.

	$n_1, n_2$	$l, u$	runs
Moisture	8,8	5,13	7
Dry Ash	8,8	5,13	6
Dry Sulfur	4,8	3,i	6
AR Btu	8,8	5,13	7

The number of runs for all characteristics falls within the closed interval ( $l, u$ ) for  $p = 4$ . Thus, there is insufficient evidence to reject the assumption of independence of the individual bias test differences. Due to the precision of analysis of sulfur, being limited to two significant digits, resulted in an indeterminate upper limit for independence. Since 5 of the 17 sets showed a zero difference in sulfur, this reduced the number of runs (differences of zero are ignored in counting runs.). Therefore the significance of the independence of data is adequate, and this result was disregarded. We may proceed to calculate confidence intervals for bias.

#### 5.0 Conclusions Regarding Bias

Walsh averages of the differences were calculated and confidence limits determined. Concluding statements are as follows:

If a chance error, which prior to the test had a maximum probability of occurring equal to no more than about 1 in 20, did not occur, biases of mechanically collected samples against stopped-belt reference samples lie within the closed intervals given below.

Moisture	$-1.485 \leq b(m) \leq 0.215$
Dry Ash	$-0.970 \leq b(arash) \leq 0.265$
Dry Sulfur	$-0.015 \leq b(arsulfur) \leq 0.015$
AR Btu	$-171.5 \leq b(arhv) \leq 369.5$

B(m), b(arash), b(arsulfur), and b(arhv) represent moisture, ar ash, ar sulfur, and ar heating value biases, respectively.

The confidence interval for the four coal characteristics tested includes the value zero. Thus, this test offers insufficient evidence to reject a hypothesis of no bias of system samples against stopped-belt reference samples. Therefore the hypothesis of no bias in these parameters is accepted.

The point estimates of biases for the four parameters studied (the median value of Walsh averages) are as follows:

Moisture =	-0.64
Ar Ash =	-0.265
Ar Sulfur =	-0.005
Ar HV =	+138

Respectfully submitted,

Stephen R. Smith

Table 1. Log of test conditions, stop belt times, weights of samples and clean tons per batch

Table 2. Results of evaluations using Wilcoxon non-parametric method in ASTM D6518

Title	Values	Characteristic	Appears Independent	Bias not Detected	Lower Bias Limit	Bias Estimate	Upper Bias Limit
Data Check Passed	TRUE	Moist	TRUE	TRUE	-1.485	-0.640	0.215
Number of Samples	17	Ash	TRUE	TRUE	-0.970	-0.265	0.400
Number of Characteristics	4	Sulfur	TRUE	TRUE	-0.015	-0.005	0.015
<b>Test Results Appear to be Independent</b>	<b>TRUE</b>	BTU	TRUE	TRUE	-171.5	138	369.5

Table 3. Bias test results for Moisture




Table 4. Results for As-Received Ash

Title	Values	System-Reference Sample No.	Difference-Median Plus (=1) or Minus=(-1)	Number of Runs	Median Difference
Parameter		Sys Sample No.	Ash basis		
Average Difference	Ash -0.32	SYS1 SB1	10.41 11.05	-0.300	-1
Median of Difference	Ash -0.34	SYS2 SB2	10.12 11.05	-0.020	-1
Number of Plus es	8	SYS3 SB3	9.76 8.88	0.360	SYS1
Number of Minuses	8	SYS4 SB4	9.02 9.43	0.140	SYS2
Number of Runs	6	SYS5 SB5	9.91 9.28	0.480	SYS3
Lower Independence Limit	5	SYS6 SB6	10 9.99	0.720	SYS4
Upper Independence Limit	13	SYS7 SB7	9.46 9.68	0.530	SYS5
Is Independent (True if OK, False if not independent)	TRUE	SYS8 SB8	9.39 9.92	-0.340	SYS6
		SYS9 SB9	10.06 8.74	-0.190	SYS7
				1.320	SYS8
				1.660	1
				4	
Text Result	The number of runs falls between the upper and lower bias limits. The observations within each series appear to be independent.				
Point Estimate of Bias	SB10 9.97	SYS10 SYS11	8.59 9.4	-1.380	SYS10
Lower Bias Limit	SB11 12.66	SYS11 SYS12	9.4 9.25	-3.260	SYS11
Upper Bias Limit	SB12 10.64	SYS12 SYS13	9.25 9.97	-1.390	SYS12
Not Biased	SB13 10.82	SYS13 SYS14	9.97 10.13	-0.950	SYS13
	SB14 9.51			0.620	SYS14
				0.960	1
				5	
				5	
				6	
Bias Test Result	The confidence interval for this coal characteristic includes 0; thus, the statistical analysis for this characteristic indicates the system is unbiased.				
	SB15 11.21	SYS15 SYS16	12.21 10.92	1.000	SYS15
	SB16 11.09	SYS16 SYS17	10.92 10.5	-0.170	SYS16
	SB17 10.7			-0.2	SYS17
				0.14	1
				6	
				6	
				6	




Table 5. Results for As-Received Sulfur




Table 6. Results for As-Received BTU

Title	Values	Ref. Blt ar	Ref. Sample No. basis	Blt ar	Sys. Sample No. basis	Blt ar	System-Reference Sample No.	Difference-Median Plus (=1) or Minus (= -1)	Number of Runs/Median Difference
Parameter			SB1	12840	SY51	13056	SY51	198	1
Average Difference	BTU 93.88		SB2	12819	SY52	13009	SY52	73	1
Median of Difference	117.00		SB3	13148	SY53	13048	SY53	-217	1
Number of Pluses	8		SB4	12991	SY54	12906	SY54	-85	2
Number of Minuses	8		SB5	13007	SY55	12923	SY55	-84	2
Number of Runs	7		SB6	12733	SY56	13057	SY56	-201	117
Lower Independence Limit	5		SB7	12938	SY57	13113	SY57	424	3
Upper Independence Limit	13		SB8	12804	SY58	13184	SY58	175	3
Is Independent (TRUE if OK, False if not independent)	TRUE		SB9	13169	SY59	12884	SY59	285	117
The number of runs falls between the upper and lower bias limits. The observations within each series appear to be independent.								-402	-1
Text Result									
Point Estimate of Bias			SB10	12831	SY510	13350	SY510	402	5
Lower Bias Limit	-138.000		SB11	12521	SY511	13196	SY511	558	117
Upper Bias Limit	-171.500		SB12	12835	SY512	12872	SY512	-80	6
Net Biased	366.500		SB13	12755	SY513	12872	SY513	0	117
	TRUE		SB14	13127	SY514	12884	SY514	-243	6
The confidence interval for this coal characteristic includes 0; thus, the statistical analysis for this characteristic indicates the system is unbiased.									
Bias Test Result			SB15	13121	SY515	12009	SY515	-1229	6
			SB16	12710	SY516	12824	SY516	-3	117
			SB17	12429	SY517	12888	SY517	442	7





Figure 1. Photograph of the Clean Coal Sampling System at Crossville Coal Inc



Figure 2. Photograph of the stopped belt sample collection site and cutter



Figure 3. Photograph of system save and stopped belt samples

